



City of Phoenix
OFFICE OF THE CITY ENGINEER
DESIGN AND CONSTRUCTION PROCUREMENT
200 W. Washington Street, 5th Floor
Phoenix, Arizona 85003-1611

**ARC FLASH ANALYSIS, ELECTRICAL DESIGN & INSPECTION SERVICES FOR
WATER REMOTE FACILITIES
ENGINEERING SERVICES**

WS85400011

NOTIFICATION LETTER NO. 1

OCTOBER 27, 2023

This notification letter shall become part of the Request for Qualifications for the above referenced project.

Q1. The instrumentation portion of this work, is it strictly electrical and ARC flash in nature or does it include instrumentation and control?

A1. It will be primarily focused on electrical, and instrumentation will be separate.

Q2. Will you follow a separate contract for 3rd party?

A2. Yes, like the coordination and the same with commissioning.

Q3. Is grounding and testing that is listed in the RFQ a requirement?

A3. Yes, it's going to be an activity if not already covered under the CA&I. Otherwise, we will ask you to help connect, collect the tests and to provide an attached report that comes with the ground testing.

If the CA&I has it in the scope, you will be observing to make sure the procedures are following the City's specifications.

Q4. Could the additional services requested be programming?

A4. Yes, we have a programming group, but you may be asked to do a little bit of programming. Each project may be a little bit different and would be on an as-needed basis.

All other terms and conditions remain unchanged.

Heather Roye

Heather Roye
Contracts Specialist
CITY OF PHOENIX
DESIGN AND CONSTRUCTION PROCUREMENT

*****END OF NOTIFICATION*****