



**City of Phoenix  
Office of the City Engineer  
Design and Construction Procurement**

**2017 PVC LINED CONCRETE SANITARY SEWER REHABILITATION  
WS90500272**

**ADDENDUM NO. 1**

ISSUE DATE: 4/10/2024

Bidders are hereby notified that the Bidding and Contract Documents for the above project, for which Bids are to be received on **April 23, 2024**, are amended as follows:

**CHANGES:**

Change 1 – Section 00300 – Bid Form, Section 1.4.1 Bid Schedule, is to be replaced with the following Bid Schedule.

Bid Item No.	Description	Unit	Quantity	Unit Price	Bid Price
1	Construction Layout & As-Builts	LS	1		
2	Mobilization/Demobilization	LS	1		
3	Remove Manholes Steps	EA	21		
4	Permanent Pavement Replacement, (COP Std Det P1200, Type A)	SY	337		
5	Permanent Pavement Replacement, (COP Std Det P1200, Type B)	SY	1,170		
6	ADOT Channel Access Road Restoration	1LS	1		
7	Micro-Seal Asphalt	SY	18,795		
8	Remove & Replace Curb & Gutter, to the Nearest Joint	LF	280		
9	Remove & Replace Sidewalk	SF	650		
10	Remove & Replace Concrete Ramp, to the Nearest Joint	SF	160		
11	Remove & Replace Manhole Cone for Bypass or CIPP Liner Installation	EA	9		
12	Landscape Restore in Kind	LS	1		
13	Sewer Bypass Pumping	LS	1		

Bid Item No.	Description	Unit	Quantity	Unit Price	Bid Price
14	Pipe Cleaning (2 Passes)	LF	6,164		
15	CCTV (2 Passes)	LF	6,164		
16	Detached Liner Removal (Manned Entry)	DAY	5		
17	30" CIPP Liner	LF	662		
18	33" CIPP Liner	LF	1,981		
19	36" CIPP Liner	LF	439		
20	Epoxy Coat Manhole Channel, Throat, Bench, Wall, Cone & Chimney	EA	12		
21	Epoxy Coat Manhole Channel & Bench	EA	6		
22	Epoxy Coat Manhole Channel	EA	2		
23	Epoxy Coat Manhole Chimney	EA	1		
24	Manhole Repair	EA	3		
25	Replace Manhole Frame & Cover	EA	25		
26	Cut and Reinstall Coupon for Bypass Suction Pit	EA	1		
27	Allowance – Additional Repairs & Rehabilitation	ALLOW	1	\$488,000	\$488,000
28	Allowance – Traffic Control	ALLOW	1	\$200,000	\$200,000
29	Allowance – Permits	ALLOW	1	\$20,000	\$20,000
30	Allowance – Stormwater Pollution Prevention Best Management Practice (BMPs)	ALLOW	1	\$60,000	\$60,000
31	Allowance – Uniformed, Off-Duty Law Enforcement Officer	ALLOW	1	\$50,000	\$50,000
32	Allowance – Owner's Contingency	ALLOW	1	\$426,870	\$426,870

**Base Bid** (The sum of the computed totals for Bid Items 1 through 32 only):

\_\_\_\_\_ Dollars and \_\_\_\_\_ Cents  
 (Written words)

\$ \_\_\_\_\_

**Questions and Answers:**

No.	Question	Answer
1	Are there any CCTV videos of the sewer to be rehabbed?	Yes. CCTV was performed in 2017. The videos can be accessed at the following link: <input type="checkbox"/> <a href="#">Design-Bid Build Assessments</a>
2.	Removal Notes 23 and 24 (Pavement Replacement) include an assumed pavement thickness and the clause "OR MATCH EXST WHICHEVER IS GREATER." What pavement thickness should we use for preparation of our bids?	Both construction notes include an assumed pavement section. Bids should reflect the assumed pavement thickness in removal notes 23 and 24. Anything greater than the assumed thickness will be addressed during construction as an allowance.

The balance of the specifications and instructions remain the same.

**NOTE: Bidders must acknowledge receipt of this Addendum by listing the number and date, where provided, on the **PROPOSAL P-1**.**

**END OF ADDENDUM**

