



**City of Phoenix
Office of the City Engineer
Design and Construction Procurement**

**PROJECT NO. ST83140111 16TH STREET TO 18TH STREET
PROJECT NO. ST83140113 18TH STREET & JACKSON STREET
PROJECT NO. ST83140115 INDIAN SCHOOL ROAD & N 28TH STREET
PROJECT NO. ST83140116 33RD AVENUE & TAYLOR STREET
PROJECT NO. ST83140120 32ND STREET & MONTEROSA STREET**

**ARPA LOCAL DRAINAGE MITIGATION PACKAGE 2
DESIGN-BID-BUILD**

RFX 6000001629

ADDENDUM NO. 2

ISSUE DATE: July 24, 2024

Bidders are hereby notified that the Bidding and Contract Documents for the above project, for which Bids are to be received on **Tuesday, July 30, 2024**, are amended as follows:

Q1.	Will temporary striping be accepted as a means of traffic control referencing S.P.-18?
A1.	No
Q2.	Will Contractors be allowed to use entirely precast irrigation structures?
A2.	Yes
Q3.	Please add details to the plans for irrigation structures.
A3.	The Contractor will provide shop drawings for review and approval by DOR and City.
Q4.	Will City property be accessible to Contractors for a laydown yard?
A4.	Permits and/or a city review will be required for any proposed laydown yard on City property.
Q5.	There is only one exit for the business on Indian School and 28th St that has operating hours 7 days of the week, will the contractor be responsible for any business losses incurred during construction as there will be no way to safely maintain ingress or egress to this property from Indian School while construction operations are in progress?
A5.	The Contractor shall maintain ingress and egress access to businesses during business hours.
Q6.	Please confirm the contractor will be allowed to store equipment and material within the limits of the public right-of-way, including on paved surfaces when needed.
A6.	Yes, and as long as it is secured and not a hazard to the public.

NOTE: Bidders must acknowledge receipt of this Addendum by listing the number and date, where provided, on the PROPOSAL P-1.



END OF ADDENDUM

