



**City of Phoenix**  
OFFICE OF THE CITY ENGINEER  
DESIGN AND CONSTRUCTION PROCUREMENT  
200 W. Washington Street, 5<sup>th</sup> Floor  
Phoenix, Arizona 85003-1611

**LIFT STATION 43 FORCE MAIN REHABILITATION  
CONSTRUCTION MANAGER AT RISK**

**WS90501000**

**RFx 6000001660**

**NOTIFICATION LETTER NO. 1**

**SEPTEMBER 16, 2024**

This notification letter shall become part of the Request for Qualifications for the above referenced project.

- 1Q.** Can you provide as-built drawings for pipe inside the vaults for vault #1, #2, and Broadway vault?
- 1A.** As-builts cannot be publicized. To view, email Sadie Thompson at [Sadie.thompson@phoenix.gov](mailto:Sadie.thompson@phoenix.gov) to schedule a time for viewing. Sadie is available between 8:30 am to 4:00 pm, Monday-Friday. As-builts can be viewed at Phoenix City Hall, 8<sup>th</sup> Floor.
- 2Q.** Can you provide as-builts for pipe/utilities associated with the footprint of the site? In addition, we would like to know the pipe material used and depth for each run.
- 2A.** As-builts cannot be publicized. See answer 1A above for viewing instructions. Existing force mains are DIP. Barrel 1 is ~13-ft deep, Barrel 2 is between ~13 and ~20-ft deep, and Barrel 3 is ~13-ft deep. New force main material will be HDPE and similar depths.
- 3Q.** Confirm, are the existing discharge structures all dry?
- 3A.** Existing Discharge Vaults No. 1 and No. 2 are **NOT** dry.
- 4Q.** Is the existing irrigation canals/pipe crossing at 75<sup>th</sup> Avenue not being used and could be abandoned/removed? Clarify what is in use and what is not.
- 4A.** The response from SRP is “the SRP pipe that crosses on both sides of 75<sup>th</sup> Avenue, at Broadway Road are in service. They may not be removed.”

All other terms and conditions remain unchanged.

*Heather Roye*

Heather Roye  
Contracts Specialist  
CITY OF PHOENIX  
DESIGN AND CONSTRUCTION PROCUREMENT

\*\*\*\*\*END OF NOTIFICATION\*\*\*\*\*