



**City of Phoenix  
Office of the City Engineer  
Design and Construction Procurement**

**CITY OF PHOENIX  
7TH STREET FIBER TRANSPORTATION ENHANCEMENT  
DESIGN-BID-BUILD-REBID**

**PROJECT NO. ST89340660  
FEDERAL AID NO. PHX-0(361)D  
ADOT TRACS NO. T023601C  
PROCUREPHX PRODUCT CATEGORY CODE 912000000  
RFX 6000001679**

**ADDENDUM 3**

ISSUE DATE: October 30, 2024

Bidders are hereby notified that the Bidding and Contract Documents for the above project, for which Bids are to be received on November 5, 2024, are amended as follows:

Q1.	In Addendum 1 where it states, "There are specific power requirements for the Node Cabinet, and the awarded contractor is responsible for meeting the following requirements."  1. Is the contractor required to supply the electrical wiring from the power source. 2. How far is the existing power source from the Node Cabinet location.
A1.	<b>Yes. The contractor is responsible for furnishing and installing electrical wiring from the existing power source to the node cabinet, utilizing the existing conduit, approximately 15 feet.</b>

**END OF ADDENDUM**

TECHNICAL REGISTRANT'S SEAL

