



**City of Phoenix  
Office of the City Engineer  
Design and Construction Procurement**

**ARPA LOCAL DRAINAGE MITIGATION PACKAGE 3  
DESIGN-BID-BUILD  
PROJECT NO. PW2620003, ST83140112, ST83140117,  
ST83140118, ST83140124 ARPA**

**RFX 6000001687**

**ADDENDUM NO. 1**

ISSUE DATE: November 8, 2024

Bidders are hereby notified that the Bidding and Contract Documents for the above project, for which Bids are to be received on **November 13, 2024**, are amended as follows:

Q1.	Is slurry seal the whole street or just half?
A1.	<b>Slurry seal will be per City pavement cut policy, so half if applicable or full if shown in plans.</b>
Q2.	Is there a bid schedule included?
A2.	<b>There is a bid “tab” in the bid package. One tab for all five projects. Projects will be invoiced to the City separately though.</b>
Q3.	Is there an engineers estimate? Is it in the bid package?
A3.	<b>There is an engineers estimate. It is not included in the bid package.</b>
Q4.	Are there any long lead items?
A4.	<b>Not aware of any. Straight forward in terms of quantities and materials.</b>

1. Delete the following section(s) in entirety and replace with the following section(s): Delete Information for Bidders (IFB), Sec. 108, Subparagraph 108.5, Page S.C.-21 and replace with the following:
  - a. **108 COMMENCEMENT, PROSECUTION AND PROGRESS, Replace the first paragraph of Subsection 108.5, LIMITATION OF OPERATIONS:** The Contractor shall conduct the work at all times in such a manner and sequence that will assure the least interference with traffic and inconvenience to the public. The Engineer may require the Contractor to finish a section on which work is in progress before work is started on any additional sections if the opening of such section is essential to public convenience. The work shown on the plan set labeled as project **ST83140124 48th PL & FLOWER ST**, shall commence between the 26<sup>th</sup> of May 2025 and no later than the final business day of May 2025 and be completed within 60 calendar days and the work shall progress in a prompt manner until all the work on this location is completed. The contractor shall coordinate and cooperate with the property owner to maintain access and use of the premises, mitigating impacts and inconveniences to the property owner at no additional cost. The Contractor

shall submit their preferred sequence to complete all four project locations (**Project PW26220003** and **ST83140112** are considered as two phases of one location). Unless approved in writing by the Engineer, the Contractor may not work at more than one of the four identified project locations identified in the bid package. If sequencing needs to be modified for some reason, Contractor shall inform the Engineer and obtain prior approval before changing sequencing.

**NOTE: Bidders must acknowledge receipt of this Addendum by listing the number and date, where provided, on the PROPOSAL P-1.**

**END OF ADDENDUM**

