

ADDENDUM 1

(please sign and return with the submittal)

CHANGES

1. Attachment B – Pricing Proposal is hereby deleted in its entirety and replaced with the “Addendum 1 – Attachment B – Pricing Proposal (Version 2.0)” that is attached separately to this addendum.

VENDOR’S INQUIRIES AND CITY’S RESPONSES

Please make the following changes to the above-referenced solicitation:

QUESTIONS AND ANSWERS:

Note: Spelling, grammar, and punctuation of the questions are shown exactly as submitted by the potential respondents.

No.	Question	Answer
1.	I want to bring up the HVAC price sheets. I noticed on the forms they specify 14 seer. The new guidance from ADOH states that we need to meet ‘seer 2 requirements’ which could mean any seer from 14-17. There is not a requirement for strictly 14 seer. I do believe there is verbiage for flexibility with HVAC units. Would you like us to continue with the forms as is or do you think they need to be revised?	<p>Please see the attached separately “Addendum 1 – Attachment B – Pricing Proposal (Version 2.0).</p> <p>Any reference to 14-SEER has been replaced with “15-SEER2, or equivalent”.</p> <p>The City of Phoenix is requesting pricing for 15-SEER2, or equivalent, on the price sheet. As such, please provide pricing accordingly.</p> <p>Equipment specifications are subject to change due to Department of Energy (DOE), Arizona Department of Housing (ADOH), and other agencies and organizations that determine Weatherization Assistance Program guidelines and regulations.</p> <p>Should the guidelines be changed in the future to reflect another SEER rating, the contract will be amended to be in line with those guidelines and/or regulations.</p>

The balance of the specifications and instructions remain the same. Bidder must acknowledge receipt and acceptance of this addendum by signing below and returning the entire addendum with the bid or proposal submittal.

Name of Company: _____

Address: _____

Authorized Signature: _____

Print Name and Title: _____