



City of Phoenix  
Office of the City Engineer  
Design and Construction Procurement

PROJECT NO. ND30010029  
2020-21 PARKS LIGHTING IMPROVEMENTS  
COMMUNITY DEVELOPMENT BLOCK GRANT  
DESIGN-BID-BUILD

RFX 6000001149

ADDENDUM NO. 2

ISSUE DATE: December 8, 2021

Bidders are hereby notified that the Bidding and Contract Documents for the above project, for which Bids are to be received on **Tuesday, December 14, 2021**, are amended as follows:

Questions and Answers:

Q1.	Will a turnkey solution utilizing a different manufacturer, while still meeting all on-field and off-site spill requirements be accepted for the sports lighting?
A1.	<b>Substitution requests are only allowed by or through a Prime Contractor. If an alternate manufacturer is requested to be used, it shall meet the attached specifications, and must be prior approved in writing by the City of Phoenix.</b>
Q2.	I do not see any alternate spec options for the lighting in the bid documents. However, is the City willing to consider off-grid solar lighting for the park lighting replacements?
A2.	<b>There are no alternate specification options for solar lighting. This question was submitted after the deadline of at least twelve days prior to bid date, per substitution request guidelines in the bid documents.</b>
Q3.	Do you have an Engineers Estimate for the cost for this project?
A3.	<b>Yes, there is an Opinion of Probable Cost for the project; however, the Opinion of Probable Cost is only provided at the Bid Opening.</b>
Q4.	Do you have any past plans on the lighting counts and wattages or a key from the plan that would give us the count of lights and pole, lighting fixture types and wattages?
A4.	<b>Each park plan set has a quantities list on each sheet SE2.1 which gives a count of each light fixture. A light fixture schedule and pole schedule is also included on each sheet SE3.1 of each park plan set for more details on fixture types and wattages, etc.</b>
Q5.	PDF page 39 – 201 Clearing and Grubbing “The Contractor shall completely remove the existing building shown on sheet of plans”. This item is not referenced in the bid schedule or on the plans.
A5.	<b>This section shall be removed.</b>
Q6.	PDF page 40 – 211 Fill Construction, Graded Maintenance Roads “The surface of maintenance road shall be 6” ABC compacted to a minimum of 95% density”. This item is not referenced in the bid schedule or on the plans.

A6.	<b>This section shall be removed.</b>
Q7.	PDF page 47 – 344 Soil Cement Bank Protection - This item is not referenced in the bid schedule or on the plans.
A7.	<b>This section shall be removed.</b>
Q8.	PDF page 60 – Section 350.2.8 Removal of Existing Bridge – <i>“work under this item shall consist of removal of the existing bridge to allow for the construction of the new bridge.”</i> This item is not referenced in the bid schedule or on the plans.
A8.	<b>This section shall be removed.</b>

Special Provisions:

1. Delete the following sections in its entirety:
  - a. SPECIAL PROVISIONS, Item 1. 201 CLEARING AND GRUBBING, Page S.P.-1
  - b. SPECIAL PROVISIONS, Item 3. 211 FILL CONSTRUCTION, Page S.P.-2
  - c. SPECIAL PROVISIONS, Item 11. 344 SOIL CEMENT BANK PROTECTION, Page S.P.-9 thru 19
  - d. SPECIAL PROVISIONS, Item 14. 350 REMOVAL OF EXISTING IMPROVEMENTS, Page S.P.-22

Technical Specifications:

1. Add Specification: SECTION 26 5600 – Exterior Sports Lighting, Pages 26 5600-1 thru 26 5600-8

Plans Sheets:

1. Add: El Prado Park Structural Calculations Pole / Foundation Standards

**NOTE: Bidders must acknowledge receipt of this Addendum by listing the number and date, where provided, on the PROPOSAL P-1.**

Attachments:

26 5600 Exterior Sports Lighting (8 pages)

El Prado Park Structural Calculations Pole / Foundation Standards (39 pages)

**END OF ADDENDUM**

Clifford Tolman, PE  
Wright Engineering Corporation

